



British
Columbia
Construction
Association

British Columbia Construction Association
BidCentral Online Bidding for Subcontractors

401 – 655 Tye Road Victoria, BC V9A 6X5
P: (250) 475-1077 F: (250) 475-1078
E: warrenp@bccassn.com
W: www.bccassn.com or www.bidcentral.ca

PRE-BID INTERPRETATION No. 6

Date: August 4, 2020
To: All Plan Holders
Project: PEXSISEN Elementary and Centre Mountain Lellum Schools
Bid Calling Authority: HCMA Architecture + Design

As allowed under Rule 1. F. Pre-Bid Interpretations, we are hereby issuing the following clarification to all plan holders. Unless defined herein the Standard Exclusions will apply; *General Contractors are responsible to include all work that may be excluded from a BidCentral Online Bidding for Subcontractor's (BOBS) Bid as they deem necessary.* This document does not imply a requirement to include work not specified:

All Bidders and General Contractors

1. View a recording of the **July 16th BOBS Webinar** [here](#). View the BOBS User Guide [here](#).
2. The BOBS Transitional Rules referenced in Pre-Bid No. 3 has been amended with the addition of clarifications to identify the referenced protocol for bidding variances ([here](#))

Roofing

Correction from Pre-Bid Interpretation No. 5 to reflect the change in Type PW1 & PW2, this assembly now does not include gypsum roof board; the plywood sheathing is by others. General Contractors shall include for this work as they deem necessary.

Windows, Doors and Glazing

Clarification: Regarding Addendum #9, Q&A #43, this Bid shall also include the supply and installation of all door hardware related to the work of this Bid.

END

BidCentral Online Bidding for Subcontractors per;

Warren E. Perks, Administrator

All Plan Holders should insure that copies of this Pre-Bid Interpretation are forwarded to all those to whom they have issued copies of the project documents.